

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2014

2015 JUN 30 AM 9:10

City of Gulfport
Public Water Supply Name

0240003
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- ☐ Advertisement in local paper (attach copy of advertisement)
☒ On water bills (attach copy of bill)
☐ Email message (MUST Email the message to the address below)
☐ Other _____

Date(s) customers were informed: 6/5/15, 6/10/15, 6/15/15, 6/20/15, 6/25/15, 6/30/15

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ____ / ____ / ____

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: ____ / ____ / ____

- ☐ As a URL (Provide URL _____)
☐ As an attachment
☐ As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: ____ / ____ / ____

CCR was posted in public places. *(Attach list of locations)*


Date Posted: 6/26/15

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

www.gulfport-ms.gov/publicworks/drinking-water-2014.pdf

CERTIFICATION

I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.


Name/Title (President, Mayor, Owner, etc.) Water Well Manager

6/26/15
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601) 576-7800

May be emailed to:
water.reports@msdh.ms.gov

2014 Annual Drinking Water Quality Report
City of Gulfport
PWS#: 240003
May 2015

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Pascagoula Formation and Graham Ferry Formation Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Gulfport have received a moderate susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Colton Peterman at 228.868.5740. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on Tuesdays bi-weekly at 2:30 PM at the City Hall.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2014. In cases where monitoring wasn't required in 2014, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID #:0240003				TEST RESULTS				
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure- ment	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants								
5 Gross Alpha	N	2012*	1.6	6 - 1.6	pCi/L	0	15	Erosion of natural deposits
Inorganic Contaminants								
8 Arsenic	N	2014	.8	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes

10. Barium	N	2014	0169	0036 - 0169	ppm	2	2	Discharge of drilling wastes, discharge from metal refineries; erosion of natural deposits
13 Chromium	N	2014*	1.4	6 - 1.4	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
16 Fluoride	N	2014	412	174 - 412	ppm	4	4	Erosion of natural deposits, water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17 Lead	N	2012/14	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Volatile Organic Contaminants

66. Ethylbenzene	N	2014	613	545 - 613	ppb	700	700	Discharge from petroleum refineries
76 Xylenes	N	2014	004	.0005 - 004	ppm	10	10	Discharge from petroleum factories, discharge from chemical factories

Disinfection By-Products

81. HAA5	N	2014	13	2-13	ppb	0	60	By-Product of drinking water disinfection.
82 TTHM [Total trihalomethanes]	N	2014	12.56	3.18 - 12.56	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2014	7	.30 - 1.83	Mg/l	0	MDRL = 4	Water additive used to control microbes

Unregulated Contaminants

Bromochloromethane	N	2013*	.468	No Range	UG/L		MRL 0.06	Used as a fire-extinguishing fluid, an explosive suppressant, and as a solvent in the manufacturing of pesticides
Strontium	N	2014	55.4	6.918 - 55.4	UG/L		MRL 0.3	Naturally-occurring element found in the earth's crust and at low concentrations in seawater, and in some surface and ground water, cobaltous chloride was formerly used in medicines and as a germicide
Vanadium	N	2014	.293	No Range	UG/L		MRL 0.2	Naturally-occurring elemental metal; used as vanadium pent oxide which is a chemical intermediate and a catalyst

* Most recent sample. No sample required for 2014.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or manmade. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The City of Gulfport works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

A copy of the 2014 CCR for the City of Gulfport (0240003) was also posted at the following locations on June 26, 2015.

Harrison County Library (Gulfport Location)

12135 Old HWY 49
Gulfport, MS 39503

Gulfport City Hall

2309 15th St.
Gulfport, MS 39501



**City of Gulfport
Water Department**

1422 23rd Avenue
Gulfport, MS 39501
Call (228) 868-5720
8:00 AM - 1:00 PM
2:00 PM - 5:00 PM
Monday-Friday
www.gulfport-ms.gov

Keep this portion for your records

Account # 439999600
Customer # 2591900
Bill # 1453939
Current Charges Due 02/15/2015
Amount Due \$111,239.47

NAVAL CONST. BATTALION CENTER, GULFPORT
NAVAL OCEANOGRAPHIC OFFICE-MARINA GPT
US NAVY
9226 3RD AVE #159
NORFOLK, VA 23511

CITY OF GULFPORT

UTILITY BILL

Customer Copy

Customer Name				Service Address			
NAVAL CONST. BATTALION CENTER, GULFPORT NAVAL OCEANOGRAPHIC OFFICE-MARINA GPT				BROAD AVE			
Bill Number	Bill Date	Account Number - Customer Number			Current Billing Due Date		
1453939	01/30/2015	439999600 - 2591900			02/15/2015		
Description		Previous Read Date	Current Read Date	Previous Meter Reading	Current Meter Reading	Usage	Charge
SW TRANSPT		12/30/2014	01/31/2015	0	12198	12198	55,376.57
SW TREATMT							55,862.90
<p>IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER IS AVAILABLE IN THE 2014 CONSUMER CONFIDENCE REPORT AT WWW.GULFPORT-MS.GOV/PUBLICWORKS/DRINKING_WATER_2014.PDF. YOU MAY REQUEST A HARD COPY BY CALLING 228-868-5740.</p>						Total Current Billing	111,239.47
						Previous Balance	.00
						Total Amount Due	\$111,239.47

✂ Detach and return the portion below with your payment ✂

Remit To:

City of Gulfport
P.O. Box 22564
Jackson, MS 39225-2564

Please write your Account Number on your check and enclose this portion of bill with your payment.

Amount Paid

\$

Check No. _____

Service Address	Bill Number	Account # - Customer #	Current Billing Due Date	Amount Due
BROAD AVE	1453939	439999600-2591900	02/15/2015	\$111,239.47



00006042015601453939900111239471

NAVAL CONST. BATTALION CENTER, GULFPORT
NAVAL OCEANOGRAPHIC OFFICE-MARINA GPT
US NAVY
9226 3RD AVE #159
NORFOLK, VA 23511

00006042015601453939900111239471